
Item Code: 204-149-VT







| X Suitable for internal use only |
|----------------------------------|
| X Multi tube configuration |
| X LSZH |
| X Euro class B2ca-s1b,d0,a1 |

Product Overview

Excel Enbeam OM4 distribution cables have been designed specifically for internal applications.

This allows the cable to be used in internal applications with a euro class rating of B2ca.


Product Specifications

| Feature | Values |
|---|-------------------|
| Number of Cores | 48 |
| Type of tube | Tight |
| Fibre type | Multi mode 50/125 |
| Category | OM4 |
| Outer sheath material | LSZH |
| Outer sheath colour | Violet |
| Reaction-to-fire class according to EN 13501-6 | B2ca |
| Smoke development class according to EN 13501-6 | s1b |
| Euro class flaming droplets/particles according to EN 13501-6 | d0 |
| Euro class acidity according to EN 13501-6 | al |
| Outer diameter approx. | 9.2 mm |

Item Code: 204-149-VT



Cross-section diagram



Cable specifications

| Features | | Values |
|------------------------------|--------------|--------------------------|
| Tensile Strength | Long Term | 275N |
| Short term | 800N | |
| Temperature performance | Installation | -40°C to +60°C |
| | Operation | -40°C to +60°C |
| | Storage | -40°C to +60°C |
| Sub Units | | 4 |
| Sub Unit OD | | $3.0 \pm 0.1 \text{mm}$ |
| Sub Unit Material | | LSZH |
| Number of fibre per Sub Unit | | 12 |
| Peripheral Strength Member | | Aramid Yarn |
| Central Strength Member | | FRP |

Outer Sheath

| | Material | LSZH |
|----------------|---------------|---------------|
| Bending Radius | Short term | 20 x Diameter |
| Long term | 10 x Diameter | |
| Attenuation | @850 nm | ≤ 3.5 dB/km |

Item Code: 204-149-VT



| @1300 nm | ≤ 1.5 dB/km | |
|-----------------------------------|-------------|-----------------------------|
| Core Cladding Concentricity Error | | ≤ 0.5 µm |
| Cladding Diameter | | 125 ± 1 μm |
| Cladding Non-circularity | | ≤1% |
| Coating Diameter | | $125 \pm 0.7 \mu \text{m}$ |

Standards

| Applicable standard | Subject |
|---------------------------|--|
| IEC 60794-2-20:2013 | Optical fibre cables - Part 2-20: Indoor cables - Family specification for multi-fibre optical cables |
| IEC 60332-1-2:2004 | Tests on electric and optical fibre cables under fire conditions. Test for vertical flame propagation for a single insulated wire or cable. Procedure for 1 kW pre-mixed flame |
| IEC 60754-2:2011 | Test on gases evolved during combustion of materials from cables - Part 2: Determination of acidity (by pH measurement) and conductivity |
| IEC 61034-2:2005+A1:2013 | Measurement of smoke density of cables burning under defined conditions - Part 2: Test procedure and requirements |
| IEC 60793-1-1:2022 | Optical fibres - Part 1-1: Measurement methods and test procedures - General and guidance |
| IEC 60793-2-10:2017 | Sectional specification for A1 multimode fibres |
| IEC 60793-1-20:2014 | Optical fibres - Part 1-20: Measurement methods and test procedures - Fibre geometry |
| IEC 60793-1-21:2001 | Optical fibres - Part 1-21: Measurement methods and test procedures - Coating geometry |
| IEC 60793-1-22:2001 | Optical fibres - Part 1-22: Measurement methods and test procedures - Length measurement |
| IEC 60793-1-30:2010 | Optical fibres - Part 1-30: Measurement methods and test procedures - Fibre proof test |
| IEC 60793-1-41:2010 | Optical fibres - Part 1-41: Measurement methods and test procedures - Bandwidth |
| ITU G.651.1 | Characteristics of a 50/125 μm multimode graded index optical fibre cable for the optical access network |
| EN 50173-1:2018 | Information technology. Generic cabling systems - General requirements |
| EN 50575: 2014 + A1: 2016 | Power, control and communication cables — Cables for |
| | |

Item Code: 204-149-VT



| | general applications in construction works subject to reaction to fire requirements |
|--|--|
| EN 50399:2011+A1:2016 | Common test methods for cables under fire conditions. Heat release and smoke production measurement on cables during flame spread test. Test apparatus, procedures, results |
| ISO/IEC 11801-1:2017 | Information technology - Generic cabling for customer premises: Part 1 General Requirements |
| ANSI/TIA 568-3.D | Optical Fiber Cabling and Components Standard |
| ANSI/TIA/EIA 598-D | Optical Fibre Cable Colour Coding |
| RoHS-II/-III (2011/65/EU & 2015/863): 2023 | Our products, demonstrate full adherence to the regulatory stipulations of the EU Directive 2011/65/EU (RoHS-II) and its corresponding delegated directive 2015/863 (RoHS-III). |
| WFD: 2023 | Compliant to Waste Framework Directive |
| SCIP: 2023 | Compliant - Does Not Contain Substances of Concern In articles as such or in complex objects (Products) |
| POPs (EU) No 2019/1021 | EU Regulation for the restriction of Persistent Organic Pollutants. |

Part Number Table

| Part Number | Description |
|-------------|--|
| 204-149-VT | Excel Enbeam OM4 Multimode Fibre Optic Cable Multi Tube 48 Core 50/125 LSOH B2ca Violet |

Excel is a world class premium performing end to end infrastructure solution designed, Manufactured, supported and delivered without compromise.



Contact us at sales@excel-networking.com

E&OE. Excel is a registered trade name of Mayflex Holdings Ltd.