

1	Unique identification code of the product type:						
	100-914						
2 Type betch or period number or any other element ellowing identification of the construction product on required.							
	Type, batch or senal number of any other element allowing identification of the construction product as required:						
The type number of 100-914 : see the print on the cable or sticker on the box							
3	Intended use or uses of the construction produ with the applicable harmonized technical sp foreseen by the manufacturer	pecification, as	4		I trade name or registered trade mark and the manufacturer as required under Article 11(5):		
	Supply of electricity and communication in buildings and other civil engineering works with the objective of limiting the generation and spread of fire and smoke			Electric / T F	Excel Excel House Inction Six Industrial Estate Avenue, Birmingham, UK, B6 7JJ Fel : +44 (0)121 326 7557 Fax : +44 (0)121 326 1537 : CPR@excel-networking.com		
5	Where applicable, name and contact address of the authorized representative whose mandate covers the tasks specified in Article 12(2):		6		of assessment and verification of constancy of onstruction product as set out in CPR, Annex V:		
	N/A				System 3		
7 In case of the declaration of performance concerning a construction product covered by a harmonized standard:							
	<ul> <li>Notified product certification body No. 0199 performed the determination of product type, the initial inspection of the manufacturing plant and of FPC, the continuous surveillance, assessment and evaluation of the FPC and the audit testing of samples taken before placing the product on the market and issued the certificate of constancy of performance.</li> <li>Notified product certification body No. 0199 performed the determination of product type, the initial inspection of the manufacturing plant and of FPC, the continuous surveillance, assessment and evaluation of the FPC and the audit testing of manufacturing plant and of FPC, the continuous surveillance, assessment and evaluation of the FPC and the audit testing of samples taken before placing the product on the market and issued the certificate of constancy of performance.</li> </ul>						
<sup>8</sup> Declared performance:							
	Essential characteristics Performance				Harmonised technical specification		

Essential characteristics	Performance	Harmonised technical specification
Reaction to fire	Dca s2 d2 a2	<b>CE</b> EN 50575:2014+A1:2016
Dangerous substances	None	UK BS EN 50575:2014+A1:2016

The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 8. This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

Signature: Neil Payne

Date: 08/06/2025

Neil Payne (Product Manager)