

| 1     Unique identification code of the product type:       205-304 |   |  |    |                       |   |  |
|---|---|--|----|-----------------------|---|--|
|   |   |  |    |                       |   |  |
| 2   | Type, batch or serial number or any other element allowing identification of the construction product as required:  |  |    |                       |   |  |
|   | The type number of 205-304 : see the print on the cable or sticker on the box   |  |    |                       |   |  |
| 3   | Intended use or uses of the construction product, in accordance<br>with the applicable harmonized technical specification, as<br>foreseen by the manufacturer:  |  | 4  |                       | trade name or registered trade mark and<br>the manufacturer as required under Article<br>11(5):   |  |
|   | Supply of electricity and communication in buildings and oth<br>civil engineering works with the objective of limiting the<br>generation and spread of fire and smoke   |  |    | Electric /<br>T<br>F  | Excel<br>Excel House<br>Inction Six Industrial Estate<br>Avenue, Birmingham, UK, B6 7JJ<br>Fel : +44 (0)121 326 7557<br>Fax : +44 (0)121 326 1537<br>I : CPR@excel-networking.com |  |
| 5   | Where applicable, name and contact address of the authorized representative whose mandate covers the tasks specified in Article 12(2):  |  | 6  | Oystern of Systems of | of assessment and verification of constancy of<br>construction product as set out in CPR, Annex<br>V:   |  |
|   | N/A   |  |    | System 3              |   |  |
| 7   | <sup>7</sup> In case of the declaration of performance concerning a construction product covered by a harmonized standard:  |  |    |                       |   |  |
|   | <ul> <li>Notified product certification body No. 0598 performed the determination of product type, the initial inspection of the manufacturing plant and of FPC, the continuous surveillance, assessment and evaluation of the FPC and the audit testing of samples taken before placing the product on the market and issued the certificate of constancy of performance.</li> <li>Notified product certification body No. 2661 performed the determination of product type, the initial inspection of the manufacturing plant and of FPC, the continuous surveillance, assessment and evaluation of the FPC and the audit testing of manufacturing plant and of FPC, the continuous surveillance, assessment and evaluation of the FPC and the audit testing of samples taken before placing the product on the market and issued the certificate of constancy of performance.</li> </ul> |  |    |                       |   |  |
|   |   |  |    |                       |   |  |
| <sup>8</sup> Declared performance:                                  |   |  |    |                       |   |  |
|   | Essential characteristics Performance   |  | ce |                       | Harmonised technical specification  |  |
|   | Reaction to fire Dca s2 d2 a1   |  |    |                       | <b>C E</b> N 50575:2014+A1:2016   |  |

The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 8. This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

None

Signature: Neil Payns

Dangerous substances

Date: 02/04/2025

UK BS EN 50575:2014+A1:2016

Neil Payne (Product Manager)